



ལྷན་གཙོ་བོ་ - ༡ ལྷོ་གཞི་ལས་འགུལ་དབང་འཛིན།

PUNATSANGCHHU-I HYDROELECTRIC PROJECT AUTHORITY
OFFICE OF THE SUPERINTENDING ENGINEER (C & P)
BJIMTHANGKHA: BHUTAN

Tel. No. (+975)-02-471575, E-mail: seconstrasts@gmail.com



PHPA-I/SE(C&P)/146/2024/128

Date: 23/X/24

CORRIGENDUM-I

All other terms & conditions remain the same for the Tender No. PHPA-I/SE(C&P)/146-08/2024 - **“Supply and installation of CCTV camera at Bjimthangkha colony, Dam complex, Adit-I&II of HRT, O&M store, Pothead Yard and Powerhouse of PHPA-I”** following is to be amended:

1. **CCTV Cabinet Box Specifications (SL No. m):** Water & Dustproof steel cover of Width 400mm x Depth 250 mm x Height 250 mm with front door lockable with lock and key with PDU 3 point 5 Amp with power cable including LA for power and control circuit, and cable entry 50 mm dia. with waterproof rubber gasket along with heat release facility.
2. Power copper cable of 2 Core x 2.5 SQ mm shall be part of Boq item “(m) Pole Mounting box/Housing Assembly Box” as defined in the scope of work under Technical Specification.
3. Any corrigendum/addendum/errata regarding this tender shall be available only on the mentioned websites (www.phpa1.gov.bt).

-Sd-

Superintending Engineer (C&P)

